



Bangiya Gramin Vikash Bank
Nadia Regional Office
5, R.K.Mitra Lane, Patra Market
Krishnagar, Nadia, PIN-741101
E-Mail: rmnadia@bgvb.co.in
ronadia@bgvbank.co.in

Ref: BGVB/NRO/P&D/172/2024-25

DATE: 01.10.2024

NOTICE

INVITING TENDER FOR UPS LINE, LAN LINE, ELECTRICAL WORKS INCLUDING AC WIRING FOR DIGNAGAR BRANCH UNDER NADIA REGION


Bangiya Gramin Vikash Bank invites sealed tenders from Bank approved suppliers to **SUPPLY & INSTALLATION OF UPS LINE, LAN LINE, ELECTRICAL WORKS INCLUDING AC WIRING** for DIGNAGAR Branch of Vill: DIGNAGAR PO DIGNAGAR PS: Kotwali, District: Nadia PIN: 741401 as per work schedule and specification considering the following terms and conditions. Specification of works are given in the format.

Sealed quotations are invited for seeking rates of the electrical work as per requirement attached herein on or before 06.10.2024.

The interested firms/vendors can either submit their quotation in person to Nadia Regional Office on any working day during office hours or may send by post so that the same may reach this office within the stipulated date. The quotations will be opened at Nadia Regional Office on 07.10.2024 at 12 Noon. The interested vendors may be present at the time of opening of such quotations.

Terms and Conditions:

- Quotation rate will be considered on Lower (L1) rate Basis.
- Rates are to be quoted as per work schedule attached herewith.
- After expiry of the above time schedule no quotation will be accepted.
- Bank Authority reserves the right to accept or cancel bid unilaterally without assigning any reason thereof prior to the placement or supply order/signing contract thereby.
- Supply of the articles and finish of the stipulated work are to be done in due time and any deviation/ delay may attract penalty from original bill.
- Materials will be rejected if any defect/ deviation in quality from specification is found as given in tender process.
- Firms must have GST registration number.
- The rate/s will be inclusive of delivery charges & others but exclusive GST.



Regional Manager
Bangiya Gramin Vikash Bank
Nadia Regional Office

Specification of the Electrical work.
For DIGNAGAR Branch

Sl. No	PARTICULARS	Quantity	RATE (Rs)	Amt in Rs.
01	Supply and fitting 100 Amp Cutout	3 No		
02	Supply and fitting Wooden Board	1 No		
03	Supply and Fitting TPN Main Switch	1 No		
04	Supply and Connection 63 amp 4 pole Busbar	1 No		
05	Supply and Fitting 63 Amp Change Over with In closer	1 No		
06	Supply and Fitting 32 Amp DP MCB with Metal MCB Box	1 Set		
07	Supply and Fitting 4 way TPN Single Door DB Box with 1 No 63 Amp 4 Pole Isolator and 12 No 16/25 Amp SP MCB for AC	1 Set		
08	Supply and Connection 10 Sqmm Copper Wire	12 Mtr		
09	Supply and Fitting 12 way SPN Single Door DB Box with 1 No 32 Amp DP MCB and 6 No 6/10 Amp SP MCB for Computer Point	1 Set		
10	Supply and Fitting 2 no 6 Amp and 1 No 16 Amp Socket and 2 No 6/16 amp Switch with Board and Plate	9 Set		
11	Supply and Fitting 2 No 4 and No 2.5 Sqmm Copper Wire in PVC Pipe	90 Mtr		
12	Supply and Fitting 16 Sqmm aluminum 4 Core Armored Cable	15 Mtr		
13	Supply and Fitting 25 Sqmm aluminum 4 Core Armored Cable	12 Mtr		
14	Supply and Fitting 2 No 2.5 and No 1.5 Sqmm Copper Wire in PVC Pipe	96 Mtr		
15	Supply and Digging 1 No 6 Fit Copper Chemical Earth Pipe with 1 Bag Earth Chemical	2 No		
16	Supply and Fitting 2 Core Armored 1.5 Sq mm Copper Cable	20 Mtr		
17	Supply and Fitting 1 no 16 Amp Socket and 1 No 25 Amp AC Stater with Board and Plate	4 Set		
18	Supply 2 Fit LED Tube	2 No		

Specification of the LAN work


Sl. No	PARTICULARS	Quantity	RATE (Rs)	Amt in Rs.
1	Supply and Fitting CAT 6 D - Link LAN Cable in PVC Pipe	150 Mtr		
2	Supply and Connection CAT 6 D - Link IO Box	7 Set		
3	Dismantle Old Rack and Re Fitting at New Premises	LS		
4	Dismantle Old UPS and Batteries Re Fitting at New Premises	2 Set		


Regional Manager
 Bangiya Gramin Vikash Bank
 Nadia Regional Office

GENERAL GUIDELINES:

- Modification of Main Electrical Panel to be done in such way that main electric supply can be routed through electric distribution board to feed two separate lines i.e. one for office/branch and other for Fire and Security Gadgets through UPS (If not already implemented).
- Switch off all electric equipment's of branch/office except security & safety gadgets.
- Besides using the ISI marked wire, the wire should be from reputed makes with Flame Retardant Low Smoke features, all the wiring should be routed through MS/PVC conduit.
- Use electrical accessories of reputed companies only. Such products should conform to latest BIS. For example: -
 - ❖ Wiring/cables- Finolex, Polycab, Havells, RR Kabel, Anchor, KEI or equivalent make.
 - ❖ Switches & sockets- Anchor, ABB, Schindler Electric, Crabtree, MK Electric (India), Legrand, North West or equivalent make.
 - ❖ MCB/ MCCB/ DB- L&T, ABB, Schneider Electric, Havells, Legrand or equivalent make.
 - ❖ Wall Fans- Crompton & Greaves, Havells, Bajaj, USHA, Orient or equivalent make.

BY ORDER


Regional Manager
Bangiya Gramin Vikash Bank
Bangiya Gramin Vikash Bank
Nadia Region
Regional Office